



Running Contract Details	
Equipment Name	5 kVA UPS System
Running Contract Valid Till	16-01-2020
Tender Ref No	KMSCL/EP/T247/204B/2017
Tendered Quantity	40
Supplier Name	M/s Hykon India Pvt. Ltd
GST No	32AAACH6869H1ZH
Installation & Delivery Period	6 Week(s)
Up-time / PM vist	95% & 4 Visits per year
Warranty period	3 Years

Supplier`s Details		
Address	Contact Details	
T C 2/1420/3 Vydhuthi Bhavan Road Pattom Trivandrum.	Contact Person	Mr. Ratheesh
	Phone	
	Mobile No	9846104910
	Email	tvm@hykonindia.com

Item-wise Price Details				
#	Item Details	Unit Rate (Incl.all taxes & charges)	Service Charges (Through KMSCL)	Grand Total
1	5 kVA UPS System <i>Model & Make : AEB 5000 / Hykon India Pvt. Ltd</i>	147124.76 Incl.GST :18%	10298.73	157423.49
		147124.76	10298.73	157423.49

Annual / Comprehensive Maintenance Charges (Exl.Tax)							
Rate	4 th Year	5 th Year	6 th Year	7 th Year	8 th Year	9 th Year	10 th Year
5 kVA UPS System							
Labour	2,900.00	2,900.00	2,900.00	3,900.00	3,900.00	3,900.00	3,900.00
Comprehensive	4,900.00	4,900.00	4,900.00	5,900.00	5,900.00	5,900.00	5,900.00

Other terms & conditions

1. The supplier shall execute an agreement with the purchaser as per tender conditions (agreement format is given in the tender

document).

2. The supplier shall submit performance security amounting to 5% of the value of the supply order.
3. The labour & comprehensive charges of equipment after the completion of warranty period is finalized by KMSCL as mentioned above.
4. Since discount rate is not applicable for equipment under Running Contract of KMSCL, purchase/supply order can be issued directly to supplier at the given rate with tax & other charges (exclusive of KMSCL service charges).
5. If purchase/supply order is issued directly to the supplier, KMSCL service charge need not be paid. But the copy of the said order may be forwarded to KMSCL for information.

Technical Specification

Equipment :5 kVA UPS System

1. Output Power Capacity: 5KVA
2. Output Voltage : 230Vac
3. Advanced DSP Controlled UPS System.
4. IGBT Rectifier.
 1. Bypass Facility.
 2. Heavy duty charger for long backup.
 3. DC- Start Function.
 4. Surge & Short circuit protection.
 5. Full function LCD display to monitor electrical parameters.
 6. Compliance to International standards.
7. Should be supplied with Exide or equivalent Lead Acid Batteries for Backup time 3 hours. Should have minimum VAH 19,200
8. Include Battery Stand, Wiring and Connection accessories.
9. Input : Single Phase
10. The system should be approved by BIS