



Running Contract Details	
Equipment Name	Fire Extinguisher - CO2 Type
Running Contract Valid Till	28-07-2021
Tender Ref No	KMSCL/EP/T322/322A/2019
Tendered Quantity	1000
Supplier Name	M/s Cochin Suraksha Fire and Security
GST No	32APWPV7286A1ZC
Installation & Delivery Period	8 Week(s)
Up-time / PM vist	95% & 0 Visits per year
Warranty period	1 Years

Supplier`s Details		
Address	Contact Details	
Building no: 1/538F Opp.Indian oil Tanker Terminal (Emergency Gate) Irimpanam Seaport - Airport Road Cochin -682 309	Contact Person	Mr. Renjith Vijayan
	Phone	
	Mobile No	8547415654, 8281505634
	Email	cochinsuraksha@yahoo.com,

Item-wise Price Details				
#	Item Details	Unit Rate (Incl.all taxes & charges)	Service Charges (Through KMSCL)	Grand Total
1	Fire Extinguisher - CO2 Type <i>Model & Make : VFP Co2 6.5 / Vintex Fire Protection Pvt Ltd</i>	8484.2 Incl.GST :18%	593.89	9078.09
		8484.2	593.89	9078.09

Other terms & conditions

1. The supplier shall execute an agreement with the purchaser as per tender conditions (agreement format is given in the tender document).
2. The supplier shall submit performance security amounting to 5% of the value of the supply order.
3. The labour & comprehensive charges of equipment after the completion of warranty period is finalized by KMSCL as mentioned above.
4. Since discount rate is not applicable for equipment under Running Contract of KMSCL, purchase/supply order can be issued directly to supplier at the given rate with tax & other charges (exclusive of KMSCL service charges).

5. If purchase/supply order is issued directly to the supplier, KMSCL service charge need not be paid. But the copy of the said order may be forwarded to KMSCL for information.

Technical Specification

Equipment :Fire Extinguisher - CO2 Type

1. Should have a capacity of at least 6kg.
2. Should be applicable for Class B and C fires.
3. Should be mounted on a Trolley for easy movement.
4. Extinguishing Agent shall be Carbon dioxide Gas.
5. Should have Squeeze grip for easy operation and no hand injuries due to ice freezing.
6. Should have controllable discharge mechanism.
7. Should have a minimum throwing distance of 2 meters for extinguishing agent.
8. Should have ISI Certification.
9. The sheet metal should have a thickness of at least 4.5mm
10. Should have warranty for at least 1 Year.
11. Any refill required for the unused cylinders during the warranty period shall be done free of cost.
12. The pressure maintained inside the extinguisher should be 10 bars