



Running Contract Details	
Equipment Name	FIRE EXTINGUISHER - VARIOUS TYPE
Running Contract Valid Till	31-08-2020
Tender Ref No	KMSCL/EP/T269/322/2018
Tendered Quantity	500
Supplier Name	M/s Cochin Suraksha Fire and Security
GST No	32APWPV7286A1ZC
Installation & Delivery Period	6 Week(s)
Up-time / PM vist	95% & 0 Visits per year
Warranty period	5 Years

Supplier`s Details		
Address	Contact Details	
Building no: 1/538F Opp.Indian oil Tanker Terminal (Emergency Gate) Irimpanam Seaport - Airport Road Cochin -682 309	Contact Person	Mr. Renjith Vijayan
	Phone	
	Mobile No	8547415654, 8281505634
	Email	cochinsuraksha@yahoo.com,

Item-wise Price Details				
#	Item Details	Unit Rate (Incl.all taxes & charges)	Service Charges (Through KMSCL)	Grand Total
1	Fire Extinguisher - Pressurized Powder Type 2 kg <i>Model & Make : VFPA2 / Vintex Fire Protection Pvt.Ltd</i>	1519.84 Incl.GST :18%	106.39	1626.23
2	Fire Extinguisher - Pressurized Powder Type 4 kg <i>Model & Make : VFPA4 / Vintex Fire Protection Pvt.Ltd</i>	2109.84 Incl.GST :18%	147.69	2257.53
		3629.68	254.08	3883.76

Other terms & conditions

1. The supplier shall execute an agreement with the purchaser as per tender conditions (agreement format is given in the tender document).
2. The supplier shall submit performance security amounting to 5% of the value of the supply order.
3. The labour & comprehensive charges of equipment after the completion of warranty period is finalized by KMSCL as mentioned above.

4. Since discount rate is not applicable for equipment under Running Contract of KMSCL, purchase/supply order can be issued directly to supplier at the given rate with tax & other charges (exclusive of KMSCL service charges).

5. If purchase/supply order is issued directly to the supplier, KMSCL service charge need not be paid. But the copy of the said order may be forwarded to KMSCL for information.

Technical Specification

Equipment :Fire Extinguisher - Pressurized Powder Type 2 kg

I. Fire Extinguisher - Pressurised Powder type – 2 Kg

1. Should be applicable on Class A, B, C and electrically started fire
2. Should have a Capacity of 2 kg
3. The pressurizing agent should be Dry Nitrogen
4. Extinguishing agent shall be Mono Ammonium Powder(ABC)-grade 90(MAP-90)
5. Should have a pressure gauge
6. Should have controllable discharge mechanism
7. Should have minimum throwing distance of 2m for extinguishing agent
8. Should have ISI Certification
9. Should have warranty for at least 5 Years.
10. Any refill required for the unused cylinders during the warranty period shall be done free of cost.
11. The product should be NABL Approved.
12. The pressure maintained inside the extinguisher should be 10 bars

Equipment :Fire Extinguisher - Pressurized Powder Type 4 kg

II. Fire Extinguisher - Pressurized Powder type - 4Kg

1. Should have capacity of 4 Kg.
2. Should be applicable on Class A, B, C and electrically started fire
3. The pressurizing agent should be Dry Nitrogen
4. Extinguishing agent shall be Mono Ammonium Powder(ABC)-grade 90(MAP-90)
5. Should have a pressure gauge
6. Should have controllable discharge mechanism
7. Should have minimum throwing distance of 4m for extinguishing agent
8. Should have ISI Certification.
9. Should have warranty for at least 5 Years.
10. Any refill required for the unused cylinders during the warranty period shall be done free of cost.

11. The product should be NABL Approved.

12. The pressure maintained inside the extinguisher should be 10 bars.